



Product Service

CERTIFICATE

No. Z10 040393 0033 Rev. 01

Holder of Certificate: **Euchner GmbH + Co. KG**

Kohlhammerstr. 16
70771 Leinfelden-Echterdingen
GERMANY

Certification Mark:



Product: **Access-Control System**

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the Testing, Certification, Validation and Verification Regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 717501876

Valid until: 2030-05-12

Date, 2025-05-13

(Christian Dirmeier)



CERTIFICATE

No. Z10 040393 0033 Rev. 01

Parameters:

Rated voltage:	DC 24V +10% / -15%
Rated input current:	max. 500mA
Operating temperature:	-20°C... +55°C

Tested according to:

2006/42/EC
 EN ISO 14119:2013
 EN 61508-3:2010 (SIL 3)
 EN ISO 13849-1:2023 (Cat. 4, PL e)
 EN IEC 62061:2021 (maximum SIL 3)
 EN 60947-5-3:2013

Model(s): Multifunctional Gate Box MGB

Nomenclature of Multifunctional Gate Box MGB:

MGB-xxxxxx-xx-x-xxxxxx

I II III IV

with:

- I Packing Units**
 - L0/L1/L2 Locking Module
 - H Handle Module
 - E Escape Release Module
 - B Bus Module
 - C Control Module
- II Bus System**

First 2 digits: Bus

 - AS ASi
 - PN ProfiNet
 - AR Series circuit
 - AP Single circuit
 - EI Ethernet/IP

Last digit: Transponder

 - A Unicode
 - C Multicode
- III Door Hinge**
 - R DIN Right
 - L DIN Left
- IV ID**
 - 6 digits