



# CERTIFICATE

No. B 040393 0022 Rev. 02

**Holder of Certificate:** **Euchner GmbH + Co. KG**

Kohlhammerstr. 16  
70771 Leinfelden-Echterdingen  
GERMANY

**Certification Mark:**



**Product:** **Switches**  
**Safety Door Switch**

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the Testing, Certification, Validation and Verification Regulations of TÜV SÜD Group have to be complied. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:** 73587303-01

**Valid until:** 2031-08-19

**Date,** 2026-09-01

( Shigehisa Ishikawa )

# CERTIFICATE

No. B 040393 0022 Rev. 02

**Model(s):** **NQ series**

| Model       | Switch configuration |
|-------------|----------------------|
| NQ02VZ-5000 | 2NC                  |
| NQ03VZ-5000 | 3NC                  |
| NQ11VZ-5000 | 1NC+1NO              |
| NQ12VZ-5000 | 2NC+1NO              |

## Parameters:

|                                              |                                                                          |
|----------------------------------------------|--------------------------------------------------------------------------|
| Utilization category:                        | AC15: 0.75 A, 240 V AC<br>DC13: 0.27 A, 250 V DC<br>DC13: 2.3 A, 30 V DC |
| Rated insulation voltage:                    | 300 V                                                                    |
| Rated conventional free air thermal current: | 2.5 A                                                                    |
| Pollution degree:                            | 3                                                                        |
| Degree of protection:                        | IP67                                                                     |

## Remarks:

- When installing / inserting the equipment, all requirements of the mentioned test standard must be fulfilled.
- See "1.4 Technical Data" on Technical Report No. 73587303 Rev.1.

**Tested according to:** EN 60947-5-1:2017  
GS-ET-15E:2019